

Mandatory Language for Monitoring and Reporting Violation
Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE

The **Dripping Springs** WSC water system PWS ID **TX1050013** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This/These violation(s) occurred in the monitoring period(s) 10/01/2025-12/31/2025

We are taking the following actions to address this issue:

The reporting was completed immediately upon receipt of Notice and DSWSC expects to be in compliance upon submission of Certificate of Delivery to TCEQ.

The DSWSC staff will create an internal automated schedule for timely submission for all future reporting.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Coralin Taylor** at 512-858-7897.

Posted /Delivered on: 5/10/2026
